

**APPENDIX-L**  
**FORM 'S'**  
 [See Rule 87 (5)]  
**Fire Audit Report Year 2021-2022**

To

1. Name: - KAMLA RAJA GIRLS GOVERNMENT POST GRADUATE COLLEGE.

Address: - J. A HOSPITAL LASHKAR, KAMPOO, GWALIOR, (M.P.)

Occupancy: - EDUCATIONAL BUILDING

Sir,

**Sub: Submission of fire audit report of building name M/S KAMLA RAJA GIRLS GOVERNMENT POST GRADUATE COLLEGE. And address: J. A HOSPITAL LASHKAR, KAMPOO, GWALIOR, (M. P.).**

I TARUN GUPTA have inspected your building /premises on 30/04/2022 (Date) and checked all Fire Equipment's /installations and have completed the Fire Audit of the said Building/Premises for which Fire NOC No. NOT AVAILABLE, dated NOT AVAILABLE issued by Fire Authority.

2. Details of fire system installed are as below:-

S. NO.	Name of System	Installed or not installed (as per requirements) (give comments)	comments for working of system (attach details, if needed)
1.	Access	18 M WIDE MAIN ROAD	
2.	Wet Riser	Not Applicable	
3		1) Main Block(L) – N/A 2) Main Block(R) – N/A 3) Social Science Building 01 – N/A 4) Social Science Building 02 – N/A 5) Science Block 01– N/A 6) Science Block 02– N/A 7) Computer Science Block – N/A 8) Management Block – N/A	



Down Comer

[Signature]



		9) Institute Of Legal Studies – Required 10) Academic Block For Languages -N/A 11) Hostel - Saraswati- N/A 12) Hostel- Kaveri- N/A 13) Central Instrumentation Facility Block - N/A 14) Biotech Block- N/A	
4.	Hose Reel	NEED TO INSTALL 1) Main Block (L) – 02 No. 2) Main Block(R) – 02 No. 3) Social Science Building 01 – 02 No. 4) Social Science Building 02 – 04 No. 5) Science Block 01– 02 No. 6) Science Block 02– 03 No. 7) Computer Science Block – 04 No. 8) Management Block – 02 No. 9) Institute Of Legal Studies – 04 No. 10) Academic Block for Languages -04 No. 11) Hostel - Saraswati- 2 No. 12) Hostel- Kaveri – 02 No. 13) Central Instrumentation Facility Block -02 No. 14) Biotech Block- 03 No.	
5.	Automatic Sprinkler System	Not Applicable	
6.	Yard Hydrant	Not Applicable	
7.	Underground Tank with Draw off Connection	Not Applicable	
8.	Terrace Tanks	NEED TO INSTALL 10000 LITERS FOR EACH BLOCK	
9.	Fire Pump	Not Applicable	
10.	Terrace Pump	NEED TO INSTALL ONE 450/900 LPM 35 M HEAD PUMP AT EACH BLOCK.	
11.	First Aid Fire Fighting Appliances	1) Main Block (L) – 06 NO. 2) Main Block(R) – 06 NO. 3) Social Science Building 01 – 06 NO. 4) Social Science Building 02 – 08 NO. 5) Science Block 01– 10 NO.	SUFFICIENT FOR PREMISES.



*[Handwritten signature in green ink]*



		6) Science Block 02– 06 NO. 7) Computer Science Block – 6 NO. 8) Management Block – 04 NO. 9) Institute Of Legal Studies – 16 NO. 10) Academic Block for Languages -04 NO. 11) Hostel - Saraswati- 6 NO. 12) Hostel - Kaveri – 06 NO. 13) Central Instrumentation Facility Block -06 NO. 14) Biotech Block- 06 No.	
12.	Pressurization System	Not Applicable	
13.	Auto Detection System	Need To Install In Library And Computer Room And Server Room.	
14.	Manual operated Electrical Fire Alarm System	NEED TO INSTALL ONE AT EACH FLOOR	
15.	P.A. System with talk back facility	Not Applicable	
16.	Emergency Light	Not Applicable	
17.	Auto D.G. Set	YES 25 KVA D.G. SET	
18.	Illuminated Exit Sign	YES NEED TO INSTALL AT EACH BLOCK.	
19.	Means of Escape	ONE STAIR CASE EACH 1.5 M WIDE.	
20.	Compartmentation	YES	
21.	MCB/ELCB	YES	
22.	Fireman Switch in Lift	Not Applicable	
23.	Hose Boxes with Delivery Hose and	Not Applicable	



*[Handwritten signature in green ink]*





24.	Refuge Area	Not Applicable	
25.	Any other installation	Not Applicable	

It is certified that the Installed Fire system as given above are in working condition and safe.

Date: 30/04/2022



  
 Tarun Gupta  
 Fire Technology & Safety Engineer  
 authorized Fire Consultant By M.P. Urmia  
 Signature



Name TARUN GUPTA

